



**ADDENDUM #: 1**

**NOTICE TO CONTRACTORS**

This Addendum is prepared to supplement information presented in the Drawings and Project Manual dated November 05, 2021 for the above referenced project. All additions, changes, omissions and conditions listed herein shall become an integral part of the Contract Documents.

**PROCUREMENT AND CONTRACTING REQUIREMENTS**

- 1.

**SPECIFICATIONS**

1. Updated Section 00 0110 – Table of Contents:
  - o Added 31 6250 – RAMMED AGGREGATE PIERS
  - o Added 03 4113 – PRECAST CONCRETE HOLLOW CORE PLANKS
2. Added section: 31 6250 – RAMMED AGGREGATE PIERS
3. Added section: 03 4113 – PRECAST CONCRETE HOLLOW CORE PLANKS

**APPROVED EQUALS**

The following products have been approved for use on this project. All approved products must still meet all product specifications as listed in the product specification section.

Section	Material ID or description	Basis of Design	Approved Equal


**DRAWINGS**

1. A201A.1 – FIRST FLOOR PLAN – AREA A.1
  - o Drawing 8A/A201A.1: Added note about <WALL PAD-2> on all first floor turf East and West structure, adjusted note about <WALL PAD-3> to only be at North and South Structure.
2. A201A.2 – FIRST FLOOR PLAN – AREA A.2
  - o Drawing 8A/A201A.2: Added note about <WALL PAD-2> on all first floor turf East and West structure, adjusted note about <WALL PAD-3> to only be at North and South Structure.
3. A201B.1 – FIRST FLOOR PLAN – AREA B.1
  - o Drawing 8A/A201B.1: Added note about <WALL PAD-2> on all first floor turf East and West structure, adjusted note about <WALL PAD-3> to only be at North and South Structure.
4. A201B.2 – FIRST FLOOR PLAN – AREA B.2

- Drawing 8A/A201B.2: Added note about <WALL PAD-2> on all first floor turf East and West structure, adjusted note about <WALL PAD-3> to only be at North and South Structure.
- 5. A201C – FIRST FLOOR PLAN - AREA C
  - Drawing 8A/A201C: Adjusted Work Room 1SC132 to accommodate new corridor bench.
  - Consult 1SC105: Add F4 wall to east elevation to hide structural brace up to 6" above ceiling. Move TV from south wall to center on new east wall.
  - Managers' Office 1SC110: Add F4 wall to east elevation down to north window jamb of window BL18 to hide structural brace up to 6" above ceiling.
- 6. A201D – FIRST FLOOR PLAN - AREA D
  - Drawing 8A/A201D: Adjusted chase at Board Room D130 to align with entrance condition.
- 7. A202B.1 – MEZZANINE FLOOR PLAN – AREA B.1
  - Updated Material ID from BAT-1 to BAT-2.
- 8. A202C – MEZZANINE FLOOR PLAN – AREA C
  - Revised mail slot casework, wall type, and dimensions.
- 9. A210A – ENLARGED PLANS AND ELEVATIONS
  - Enlarged Plan 3A/A210A: Shifted sinks, toilets, toilet partitions, wall, countertop, mirrors, and FFE to allow door flip.
  - Elevation 6A/A210A: Shifted sinks, mirrors, tile and countertop south, adjusted dimensions.
  - Elevation 8A/A210A: Shifted toilets and toilet partitions north, flipped door.
- 10. A210B – ENLARGED PLANS AND ELEVATIONS - POWER
  - Elevation 5C/A210B: Added note to coordinate shower head height with owner. Added finishes tags.
  - Elevation 8C/210B: Updated solid surface (<SSM-4>) and resilient base (<RB-2>).
  - Elevation 7F/A210B: Adjusted shelves with hanger bars to accommodate new corridor bench.
  - Elevation 8F/A210B: Adjusted tall cabinet and filler widths.
  - Enlarged Plan 3F/A210B: Adjusted south wall to accommodate new corridor bench.
  - Elevation 8A & 8B: Change countertop surface from <QTZ-2> to <SSM-4>
- 11. A211 – ENLARGED PLANS AND ELEVATIONS
  - Added elevations 6D/A211 and 7D/A211 to show metal shelf and coat hooks at TLT C211 and TLT C212.
  - Added callouts to 3D/A211 to aforementioned toilet rooms
- 12. A212 – ENLARGED PLANS AND ELEVATIONS
  - Elevation 8B/A212: Adjusted tile height to accommodate baby changing.
  - Elevation 8C/A212: Adjusted tile height.
  - Elevation 7C/A212: Adjusted tile height.
- 13. A600 – INTERIOR FINISH LEGEND
  - Update finish legend and finish information
- 14. A601 – INTERIOR ROOM FINISH SCHEDULE
  - Update Remarks column to remove wall protection from room 1SC160 Corridor
- 15. A601C – FIRST FLOOR FINISH PLAN – AREA C
  - Work Room 1SC132: Adjusted WP-1 locations on south wall.
  - Clarification Pool Therapies 1SC186: Tile finishes for this space are under Alternate 10. Base bid: Fill in pit opening with steel stud framing and ¾" T&G plywood. Walls to be painted gypsum board.
- 16. A610 – INTERIOR ELEVATIONS
  - Elevation 6B/A610: Updated clarifying mailbox pass-thru dimensions.
  - Elevation 7B/A610: Updated clarifying mailbox pass-thru dimensions.
- 17. A611 – INTERIOR ELEVATIONS – ADMIN
  - Elevation 4C/A611: Provided clarifying cabinet dimensions.
- 18. A612 – INTERIOR ELEVATIONS – POWER
  - Elevation 3C/A612: Adjusted Hockey Treadmill Lobby casework to meet ADA requirements
  - Elevation 7C/A612: Adjusted Hockey Treadmill cuddies to meet ADA requirements.
  - Elevation 8D/A612: Changed note <SSM-3> to <PLAM-6>

- Elevation 4D/A612: Replaced south elevation with new east elevation showing TV centered in room.
- 19. A613 – INTERIOR ELEVATIONS – POWER
  - Added Elevation 5F/A613 to show new bench and cubbies at Corridor 1SC108.
  - Added note to Elevation 8E to paint louver above door <HPC-4>
  - Elevation 3F/A613: Furred out wall, see floor plan.
- 20. A620 – Casework Schedule
  - Deleted details 6D/A620 and 7D/A620.
  - Added detail 6D/A620 - Corridor 1SC108 cubbies.
  - Detail 3B/A620: Adjusted height to meet ADA requirements.
  - Detail 5C/A620: Adjusted height to meet ADA requirements.
  - Detail 7B/A620: Revised mailbox pass-thru detail.
- 21. A622 – SIGNAGE PLAN DETAILS
  - Detail 3B/A622: Revised letter type to be surface mounted aluminum lettering.
  - Detail 5B/A622: Revised lettering to be painted steel.
- 22. A701C – RCP FIRST FLOOR – AREA C
  - Work Room 1SC132: Revised ceiling to accommodate Corridor 1SC108 bench and cubbies.
  - Corridor 1SC108: Added gypsum soffit at new bench location.
  - PT GYM 1SC136 & CORRIDOR 1SC108: Added gridlines to ceiling to show ACT layout.
- 23. A701D – RCP FIRST FLOOR – AREA D
  - Added gyp bd soffit above wall casework at Corridor D100.
  - Adjusted ceiling gypsum and act boundaries at Board Room D130.
- 24. A701E – RCP FIRST FLOOR – AREA E
  - Updated gym curtain divider material ids.
- 25. A701F – RCP FIRST FLOOR – AREA F
  - Toilet E112 to be <GYP BD-1> in lieu of <ACT-1>.
- 26. A702A.1 - RCP MEZZANINE – AREA A.1:
  - Added keynote <GYM CRTN-1>
- 27. A702A.2 - RCP MEZZANINE – AREA A.2:
  - Added keynotes <GYM CRTN-1> and <GYM CRTN-2>
- 28. A702B.1 - RCP MEZZANINE – AREA B.1:
  - Added keynotes <GYM CRTN-1> and <GYM CRTN-2>
- 29. A702B.2 - RCP MEZZANINE – AREA B.2
  - Revised note <GYM CRTN-1> to read <GYM CRTN-2> and added note <GYM CRTN-1>.
- 30. A702C – RCP MEZZANINE – AREA C
  - Revised lighting orientation in rooms C239, C240, C241.
- 31. A702E – RCP MEZZANINE – AREA E
  - Added (4) keynotes for <BBALL-3>
- 32. A720 – RCP DETAILS:
  - Added typical detail SOFFIT ABOVE CASEWORK 8D/A720.
- 33. A802C – MEZZANINE FFE PLAN – AREA C
  - TLT C211 and TLT C212: Added equipment E53 and coat hooks.
- 34. A810 – COURTS STRIPING PLANS
  - Plan 6A/A810: revised main court striping location and dimension.
- 35. A914 – ALT #5 COURTS STRIPING PLANS
  - Plan 3A/A914 cross basketball court striping plan: Added keynote 5.

END OF ADDENDUM



November 15, 2021

JLG Architects  
Fargo Sports Complex  
Fargo, North Dakota  
JLG Project # 16182

## **ADDENDUM NO. 1**

Drawings and Project Specification Manual for the above referenced project are hereby revised in accordance with the items set forth herein. This Addendum supersedes and supplements all portions of the Bidding Documents with which it conflicts.

Receipt of this Addendum shall be acknowledged by entering this Addendum number on your proposal.

### **CHANGES TO THE DRAWINGS**

#### **Sheet C300 – Storm Sewer Plan**

- a) Storm Manhole #31 size changed to 72".
- b) Storm Manhole #35 size changed to 84".
- c) Storm Manhole #41 size changed to 72".

#### **Sheet C301 – Storm Sewer Plan**

- a) Storm Manhole #5 size changed to 84".
- b) Storm Manhole #16 size changed to 72".
- c) Storm Manhole #23 size changed to 60".
- d) Storm Manhole #28 size changed to 72".

#### **Sheet C302 – Alternate Storm Sewer Plan**


- a) Storm Manhole #41 size changed to 72".
- b) Storm Manhole #49 size changed to 72".
- c) Storm Manhole #50 size changed to 72".
- d) Storm Manhole #52 size changed to 72".
- e) Storm Manhole #54 size changed to 84".
- f) Storm Manhole #55 size changed to 72".
- g) Storm Manhole #56 size changed to 60".
- h) Storm Manhole #59 size changed to 60".
- i) Storm Manhole #61 size changed to 60".

#### **Sheet C500 – Grading Plan – Points**

- a) Grading around the north doors at Area A.1 has been revised.

#### **Sheet C501 – Grading Plan – Points**

- a. A stoop and sidewalk were added in Area D.



Sheet C502 – Grading Plan – Contours

- a) Grading around the north doors at Area A.1 has been revised.

Sheet C503 – Grading Plan – Contours

- a) A stoop and sidewalk were added in Area D.

Sheet C600 – Paving Plan

- a) Stoops and sidewalk around the north doors at Area A.1 have been revised.
- b) Stoop and sidewalk adjustments were made around the building.

Sheet C601 – Paving Plan

- a) A stoop and sidewalk were added in Area D.
- b) Stoop and sidewalk adjustments were made around the building.

**END ADDENDUM NO. 1**



<b>Fargo Office</b>	<b>Sioux Falls Office</b>
4180 24th Avenue S	436 E 8th Street
Fargo, ND 58104	Sioux Falls, SD 57103
(701) 280-0949	(605) 370-6139

**Fargo Sports Complex**  
**Fargo, ND**  
**11/16/2021**  
**Project Number 039.0133.2018**

**Addendum #1 (Structural)**

**The following additions, clarification, deletions, and/or changes shall be made to the DRAWINGS:**

1. Sheet S001 – GENERAL STRUCTURAL NOTES
  - a. Addition of Column's C12 and C13 to the column schedule.
2. Sheet S101A.1 – FTG. & FDN. PLAN – AREA A.1
  - a. Modification to the overhead door area between grids A7 & A9.
3. Sheet S101D – FTG. & FDN. PLAN – AREA D
  - a. Modifications to dimensions between grids DO, D0.5, DP, and DQ.
  - b. Addition of the stoop between grids DR and DS.
4. Sheet S202A.1 – MEZZ. FRMG. PLAN – AREA A.1
  - a. Modification to the overhead door area between grids A7 & A9.
5. Sheet S204C – ROOF FRAMING PLAN – AREA C
  - a. Addition of detail cut along grid CA near C2.
6. Sheet S204F – ROOF FRAMING PLAN – AREA F
  - a. Callout of the columns for the two hanging partition walls near grid F7.2 and F8.3.
7. Sheet S402 – FRAMING DETAILS
  - a. Addition of detail 33/S402
8. Sheet S403 – FRAMING DETAILS
  - a. Modification of detail 1/S403.
  - b. Modification of detail 2/S403.
  - c. Modification of detail 3/S403.
9. Sheet S921D – STRUCTURAL PLANS – AREA D ALTERNATE
  - a. Addition of stoop between grids DN and DO.
  - b. Addition of three stoops along grid DR.

**End of Addendum #1 (Structural)**

## ADDENDUM – #1

Date	11/16/2021
Project #	2018222
Project Name	FARGO SPORTS COMPLEX
Project Location	Fargo, ND

---

**NOTICE TO BIDDERS:** This Addendum is prepared to supplement information presented in the Drawings and Project Manual for the above referenced project. All additions, changes, omissions, and conditions listed herein shall become an integral part of the Contract Documents.

---

## DRAWINGS

**ITEM NO. 1** H201C – FIRST FLOOR PLAN – AREA C – HVAC PIPING

- A. Thermostat locations revised as shown.

**ITEM NO. 2** V101E – FIRST FLOOR PLAN – AREA E – VENTILATION

- A. Note added for return grille out of Team Store E101.

**ITEM NO. 3** V101F – FIRST FLOOR PLAN – AREA F – VENTILATION

- A. Ductwork and grilles revised for Toilet room E112 with gypsum ceiling.

**ITEM NO. 4** V102C – MEZZANINE FLOOR PLAN – AREA C – VENTILATION

- A. Grille and diffuser layout updated where indicated.
- B. Grilles and diffusers adjusted to align with ceiling grid throughout. Quantities and general locations are the same as original issued set.

**ITEM NO. 5** M101C – ROOF PLAN – AREA C – MECHANICAL

- A. Vent through roofs on low roof areas omitted where no plumbing vent piping below.

**ITEM NO. 6** M201 – MECHANICAL CONTROL DIAGRAMS

- A. Sequence of operation revised for domestic hot water control.

## END OF ADDENDUM

## ADDENDUM – #1

Date	11/16/2021
Project #	2018222
Project Name	FARGO SPORTS COMPLEX
Project Location	Fargo, ND

---

**NOTICE TO BIDDERS:** This Addendum is prepared to supplement information presented in the Drawings and Project Manual for the above referenced project. All additions, changes, omissions, and conditions listed herein shall become an integral part of the Contract Documents.

---

## DRAWINGS

### ITEM NO. 1 E000 – ELECTRICAL TITLE SHEET

- A. Added E002 – SITE PLAN ALTERNATE – ELECTRICAL to Electrical sheet index.

### ITEM NO. 2 E001 – SITE PLAN - ELECTRICAL

- A. Add circuit id to pole lights on north road.
- B. Add provisions for two (2) future EV Charging Stations.
- C. Relocate two (2) receptacles on Light poles.
- D. Delete Panel CS1 for sheet.
- E. Relocate monument sign from next to building to plan south four-way interception.
- F. Add provisions for monument sign at south entrance to site.
- G. Revise General Sheet Notes as noted on drawing.
- H. Revise Electrical Site Sheet Note 'ES4' as indicated on drawing.
- I. Delete Electrical Site Sheet Note 'W24'.
- J. Add Electrical Site Sheet Note 'ES7 as indicated on drawing.

### ITEM NO. 3 E002 – SITE PLAN ALTERNATE – ELECTRICAL

- A. Added provisions alternate #28, Pond Fountain and lighting on west side of site plan.
- B. Add circuit id to pole lights in alternate #11.
- C. Add provisions for two (2) future EV Charging Stations.
- D. Relocate two (2) receptacles on Light poles.
- E. Modify item in alternate #16.
- F. Relocate monument sign from next to building to plan south four-way interception.
- G. Add provisions for monument sign at south entrance to site.
- H. Revise General Sheet Notes as noted on drawing.
- I. Revise Electrical Site Sheet Note 'ES4' as indicated on drawing.
- J. Add Electrical Site Sheet Notes 'ES7', 'ES8', 'ES9' as indicated on drawing.
- K. Revise lighting layout in Enterprise Marketing SPC Room C239, Enterprise Room C240, and Enterprise Content SPC Room C241.

### ITEM NO. 1 E100.1 - FIRST FLOOR PLAN – OVERALL - ELECTRICAL

- .Delete Electrical sheet note 'W39'
- A. Add Electrical Sheet Note 'W42' as indicated on drawing.

### ITEM NO. 2 E100.2 MEZZANINE FLOOR PLAN – OVERALL - ELECTRICAL

- A. Add General Electrical Notes as indicated on drawing.



ITEM NO. 3 E101A.1 - FIRST FLOOR PLAN – AREA A.1 - LIGHTING

- A. Add 924 Relays as indicated on drawings.
- B. Relocate type Z and E1 fixtures near grid A8.
- C. Relocate 3way switch near north wall man door in Turf Storage A103.
- D. Relocate 3way switch near south man door in Turf Storage A103.

ITEM NO. 4 E101A.2 - FIRST FLOOR PLAN – AREA A.2 - LIGHTING

- A. Add 924 Relays as indicated on drawings.

ITEM NO. 5 E101B.1 - FIRST FLOOR PLAN – AREA B.1 - LIGHTING

- A. Add 924 Relays as indicated on drawings.

ITEM NO. 6 E101B.2 - FIRST FLOOR PLAN – AREA B.2 - LIGHTING

- A. Add 924 Relays as indicated on drawings.

ITEM NO. 7 E101C - FIRST FLOOR PLAN – AREA C - LIGHTING

- A. Change light fixture Type L12 to L12PP in Pool Therapies, Room 1SC186.
- B. Change light fixture Type SL to SLP in shower area of Pool Therapies, Room 1SC186.
- C. Add 924 Relays as indicated on drawings.
- D. Replace 3way switches with standard switches in PT/Power Offices 1SC140.

ITEM NO. 8 E101D - FIRST FLOOR PLAN – AREA D - LIGHTING

- A. Revise the lighting layout in Multipurpose Room. Refer to drawings for layout.

ITEM NO. 9 E101E - FIRST FLOOR PLAN – AREA E - LIGHTING

- A. Add 924 Relays as indicated on drawings.
- B. Relocate Lighting controller on northwest courts wall to next to bleachers.

ITEM NO. 10 E101F - FIRST FLOOR PLAN – AREA F - LIGHTING

- A. Add 924 Relays as indicated on drawings.

ITEM NO. 11 E102A.1 - MEZZANINE FLOOR PLAN – AREA A.1 - LIGHTING

- A. Add 924 Relays as indicated on drawings.

ITEM NO. 12 E102A.2 - MEZZANINE FLOOR PLAN – AREA A.2 - LIGHTING

- A. Add 924 Relays as indicated on drawings.
- B. Change L10W fixture at south stair to be emergency.

ITEM NO. 13 E102B.1 - MEZZANINE FLOOR PLAN – AREA B.1 - LIGHTING

- A. Add 924 Relays as indicated on drawings.

ITEM NO. 14 E102C - MEZZANINE FLOOR PLAN – AREA C - LIGHTING

- A. Add LC note to Enterprise Room C240.
- B. Add LC note to Enterprise Content SPC Room C241.
- C. Replace 3way switch with switch at north Lobby door.
- D. Move 3way switch floating at south lobby to be in wall and replace with switch.
- E. Delete type E1 fixture at south Lobby door.
- F. Relocate type E1 fixture in corridor C210.

ITEM NO. 15 E102D - MEZZANINE FLOOR PLAN – AREA D - LIGHTING

- A. Add 924 Relays as indicated on drawings.

ITEM NO. 16 E102E - MEZZANINE FLOOR PLAN – AREA E - LIGHTING

- A. Add 924 Relays as indicated on drawings.
- B. Identify switch control for perimeter lights.

ITEM NO. 17 E102F - MEZZANINE FLOOR PALN – AREA F - LIGHTING

- A. Add 924 Relays as indicated on drawings.
- B. Replace switch with 3way switch in Storage E202. Add second 3way at south door.
- C. Change two (2) h TYPE ILGHTS TO BE EMERGENCY IN Boiler / Mech Room E218

ITEM NO. 18 E201A.1 - FIRST FLOOR PLAN – AREA A.1 - POWER

- A. Relocate receptacle, and door controller at north wall at Turf Storage A103.
- B. Relocate receptacles, door controller at south wall at Turf Storage A103.

ITEM NO. 19 E201C - FIRST FLOOR PLAN – AREA C - POWER

- A. Delete Monitor receptacle in Hockey Treadmill Room 1SC176.
- B. Add junction box and key notes W42 to south wall Hockey treadmill Room 1SC176.
- C. Delete two (2) receptacles from west wall of Training/Plyometrics Room 1SC170.
- D. Change duplex receptacle at desk to quad in Training/Plyometrics 1SC170.
- E. Delete five (5) receptacles in east wall of Training/Plyometrics Room 1SC170.
- F. Delete three (3) countertop receptacles on Corridor 1SC160.
- G. Relocate shade controller to north wall in PT Gym 1SC136.
- H. Delete monitor in PT/Power Office Room 1SC140.
- I. Relocate the two (2) dedicated receptacles on east wall of Refueling Room 1SC102 to the south wall.
- J. Change one (1) duplex to a quad in reception desk in Recep. Room 1SC101 and revise layout as indicated on drawing.
- K. Delete one (1) duplex and one (1) quad receptacle in Work Room 1SC104.
- L. Change the two (2) remaining duplex to quad Receptacles on Work Room 1SC104.
- M. Relocate monitor from south wall to east wall in Consult Room 1SC105.
- N. Delete one (1) receptacle and revised layout of receptacles in Consult Room 1SC105.
- O. Delete one (1) quad receptacle in south wall in Managers Office 1SC110.

ITEM NO. 20 E201D - FIRST FLOOR PLAN – AREA D - POWER

- A. Identify circuit number to ATC Panel in Custodial/Storage Room D126

ITEM NO. 21 E201F - FIRST FLOOR PALN – AREA F - POWE

- A. Relocate two (2) receptacles in Training Room E106. Refer to drawing for locations.
- B. Make one (1) receptacle on the north wall not above the countertop on Training Room E106.
- C. Identify the circuit numbers for the two junction boxes for the signs in Corridor E120.
- D. Change the NEMA rating of receptacle in Jan/Storage E219 from NEMA 14-50R to 14-30R.

ITEM NO. 22 E202A.1 - MEZZANINE FLOOR PLAN – AREA A.1 - POWER

- A. Delete one (1) receptacle and relocate one (1) receptacle on south wall.
- B. Add receptacle and keyed note W65.
- C. Revise location of curtain motor and rename.
- D. Add equipment control relay junction box.

- E. Add keyed note W23, W64, & W65 as indicated on drawing.

ITEM NO. 23 E202A.2 - MEZZANINE FLOOR PLAN – AREA A.2 - POWER

- A. Delete one (1) receptacle and relocate one (1) receptacle on north wall.
- B. Add receptacle and keyed note W65.
- C. Revise location of curtain motor and rename.
- D. Add two (2) junction boxes for signs on the west wall.
- E. Add keyed note W64 as indicated on drawing.

ITEM NO. 24 E202B.1 - MEZZANINE FLOOR PLAN – AREA B.1 - POWER

- A. Delete one (1) receptacle on north wall.
- B. Delete one (1) receptacle and relocate one (1) receptacle on east wall.
- C. Add receptacle and keynote W65.
- D. Add equipment control relay junction box.
- E. Add key notes W64, W65, & W69 as indicated on the drawings.

ITEM NO. 25 E202B.2 - MEZZANINE FLOOR PLAN – AREA B.2 - POWER

- A. Revise location of curtain motor and rename.
- B. Add receptacle and keynote W65.
- C. Add Keynote W66 as indicated on drawings.

ITEM NO. 26 E202C - MEZZANINE FLOOR PLAN – AREA C - POWER

- A. Add dead face GFCI and keyed note W3 for water cooler outside storage C213.1.
- B. Add dead face GFCI and keyed note W3 for receptacle north in Pass-thru Kitchen C228.
- C. Add dead face GFCI and keyed note W3 for receptacle south in Pass-Thru Kitchen C228.
- D. Relocate two (2) receptacles over the sink in Conference C246.
- E. Delete floating receptacle south in Lobby C200.
- F. Relocate the two (2) quads and one (1) duplex in Ex Admin AS. Room C245.
- G. Delete motorized shades and controllers in Executive Director Room C244.
- H. Add keyed Notes W3, & W7 as indicated on drawing.

ITEM NO. 27 E202E - MEZZANINE FLOOR PLAN – AREA E - POWER

- A. Add six (6) ceiling receptacles to the courts area.
- B. Revise gym equipment ID's Add seven (7) Volleyball height adjustment connections.
- C. Add seven (7) junction boxes for gym equipment relays.
- D. Relocate gym curtain motors.
- E. Delete one (1) dead face GFCI from bleacher area.
- F. Add a junction box for sign above elevator door.
- G. Add Poke-thru type PT-A to Mezz concourse A200.
- H. Move receptacle in Midco Lounge 0885 to 96".
- I. Add key notes W65 & W66 as indicated on drawing.

ITEM NO. 28 E202F - MEZZANINE FLOOR PLAN – AREA F - POWER

- A. Add switch for fireplace control at fireplace.
- B. Delete receptacle at fireplace.
- C. Change height of monitor receptacle on south concession wall.
- D. Add 96" receptacle for monitor north side of concession wall.
- E. Add keynote W3 to dead face GFCI's near toilets.
- F. Add keynote W3 for dead face GFCI's in party rooms

- G. Delete panel HEF2 from Storage E221.
- H. Add VFD's for pumps in Storage E221.
- I. Add junction box for BAS power in Storage E221.
- J. Add VFD's for pumps in Boiler/Mech Room E218.
- K. Add keyed notes W65, and W69 as indicated on drawing.

ITEM NO. 29 E203 - ROOF PLAN - ELECTRICAL

- A. Add conduit and keynotes W67 & W68 as indicated on drawing.
- B. Add general power notes as indicated on drawing.
- C. Add circuit tag for CU-1.

ITEM NO. 30 E204 - LARGE SCALE FOOD SERVICE

- A. Add details 4, 5, 6 & 7 as indicated on drawing.

ITEM NO. 31 E301B.1 - FIRST FLOOR PLAN - AREA B.1 - TELECOMMUNICATION

- A. Moved callout bubble and moved SD Card Reader to electronic safety and security work set, removed clock

ITEM NO. 32 E301C - FIRST FLOOR PLAN - AREA C - TELECOMMUNICATION

- A. Note moved to power plan (E201C), removed J-box, removed "LD1A 27" note, added keynotes

ITEM NO. 33 E301D - FIRST FLOOR PLAN - AREA D - TELECOMMUNICATION

- A. Deleted "PT-D" labels and view 7/E531, added speakers, placed keynotes

ITEM NO. 34 E301E - FIRST FLOOR PLAN - AREA E - TELECOMMUNICATION

- A. Moved control panel locations

ITEM NO. 35 E301F - FIRST FLOOR PLAN - AREA F - TELECOMMUNICATION

- A. Deleted data outlet and speaker, placed speakers, moved clock

ITEM NO. 36 E302C - MEZZANINE FLOOR PLAN - AREA C - TELECOMMUNICATION

- A. Moved receptacles, added speaker

ITEM NO. 37 E302E - MEZZANINE FLOOR PLAN - AREA E - TELECOMMUNICATION

- A. Added scoreboard height to receptacles

ITEM NO. 38 E302F - MEZZANINE FLOOR PLAN - AREA F - TELECOMMUNICATION

- A. Changed receptacles to 4D, moved receptacle in storage

ITEM NO. 39 E401B.2 - FIRST FLOOR PLAN - AREA B.2 - ELECT. SAFETY & SECURITY

- A. Delete junction box near grid C27 and AF.

ITEM NO. 40 E401E - FIRST FLOOR PLAN - AREA E - ELECT. SAFETY & SECURITY

- A. Add callout detail for northeast double door in courts.

ITEM NO. 41 E401F - FIRST FLOOR PLAN - AREA F - ELECT. SAFETY & SECURITY

- A. Add callout detail for south double door in Courts Storage E113.
- B. Remove machinal damper symbol from Storage room E114.

ITEM NO. 42 E500 - LARGE SCALE ELECTRICAL & MECH ROOMS

- A. Change light fixture Type H to Type HPP in Large Scale Pool Pit drawing.
- B. Delete detail #3.
- C. Provide circuit ids for receptacle in detail #2
- D. Provide circuit ids for equipment in detail #6
- E. Provide circuit ids for equipment in detail #7

ITEM NO. 43 E510 – ALTERNATE #5 – AREA E - POWER

- A. Add Gym Equipment Schedule – Alt #5 to sheet and indicated.

ITEM NO. 44 E513 – FIRST FLOOR PLAN - ALTERNATE #6 – AREA D

- A. Add circuit ids to details #2.

ITEM NO. 45 E514 – MEZZANINE FLOOR PLAN – ALTERNATE #6 – AREA D

- A. Add light fixtures to detail #1
- B. Add DF-2 and junction box to detail #2
- C. Add WAP to detail #3
- D. Add fire alarm device to detail #4
- E.

ITEM NO. 46 E530 – ELECTRICAL DETAILS

- A. Add detail # 16, 17, and 18 as indicated on drawing.

ITEM NO. 47 E531 – ELECTRICAL DETAILS

- A. Edit detail #13 as indicated on drawing.

ITEM NO. 48 E532 – ELECTRICAL DETAILS

- A. Add Detail #12

ITEM NO. 49 E533 – ELECTRICAL DETAILS

- A. Delete detail #3.
- B. Modify detail #5 as indicated on drawing and change to detail #3.

ITEM NO. 50 E534 – ELECTRICAL DETAILS

- A. Modify detail #1 as indicated on drawing.
- B. Modify detail #3 as indicated on drawing.

ITEM NO. 51 E535 – ELECTRICAL ONE-LINE AND RISER DIAGRAM

- A. Delete panel HEF2 for detail #1
- B. Delete panel HEF2 from detail #2
- C. Update schedule.

ITEM NO. 52 E600 – LIGHTING FIXTURE AND SENSOR SCHEDULES

- A. Revise manufacturers and series on Light Fixture Schedule. Add Type HPP fixture type.
- B. Revise Building wide lighting control schedule as indicated.
- C. Add building lighting control system note 'H' and indicated on drawing.
- D. Revise light fixture schedule as indicated.
- E.

ITEM NO. 53 E601 – M&E SCHEDULES AND PANEL SCHEDULES

- A. Update RTU-7, & RTU-8.

ITEM NO. 54 E602 – PANEL SCHEDULES

A. Revise panel schedules as indicated on drawing.as indicated on drawing.

ITEM NO. 55 E602 – PANEL SCHEDULES

A. Revise panel schedules as indicated on drawing.as indicated on drawing.

**END OF ADDENDUM**