
ADDENDUM ONE

Project: Parshall Public School District - Elementary Addition Project (Bid Package 2)
EngTech #999-540-006

Date of Issue: June 2, 2022

Bid Due Date ~~June 2, 2022~~ June 14, 2022

NOTICE: This addendum is issued by EngTech to all known individuals, firms, or corporations who have obtained or received bidding documents and contract documents for the above listed project. This addendum shall become part of the contract documents as a revision to the original documents.

This addendum is issued to modify, supplement and/or clarify the original Bidding Documents and shall be considered supplemental thereto. Each Bidder shall indicate consideration of the Addendum by completion of the appropriate blank space on the Bid Form and shall be responsible for advising prospective suppliers and sub-contractors.

CHANGES TO DRAWINGS / SPECIFICATIONS:

1. See attached "Report of Geotechnical Exploration Program" completed by Material Testing Services. The report provides current date for borings taken at the proposed building site.
2. Reference attached sketch SK-01 for profile views of over-excavation requirements.
3. The intent is to remove all uncontrolled fill noted on the soil borings. The excavated soil will be allowed to be reused - provided it is suitable, placed and compacted in lifts. Coordinate exact requirements with the report.

END OF ADDENDUM